



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

<b>FOR OFFICE USE ONLY</b>
Facility # 2-021384
Permit # 00792-2008FLX
Request Rec'd 05/19/2008
Amended Date
Approval Date 5/19/2008 DS
Permit Expires 11/19/2008

**Permit for UPGRADE or REPAIR of FLEX CONNECTOR for existing Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair flex connector(s) is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for flex connector of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          SRJ Associates          6335 Dempster          Morton Grove, IL 60053          Contact: Stanley Matthews (847) 877-3316</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          SRJ Associates          6335 Dempster          Morton Grove, Cook Co., IL          Contact: Stanley Matthews (847) 877-3316</p>
---	---

**(3) UPGRADE OR REPAIR OF FLEX CONNECTORS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 10,000 gallons, (TK # 5) - 12,000 gallons
- (b) *Type of flex connector(s):*
- (c) *Product stored in each tank:* (TK # 1, 5) - Gasoline
- (d) *Corrosion Protection being installed with flex connector(s):* (TK # 1, 5) - (Installing) Sacrificial anodes cathodic protection in submersible sumps only

**(4) The owner must notify this Office when completion of flex connector upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for flex connector to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>          B &amp; K Equipment Company          2939 175th Street          Lansing, IL 60438</p>	<p>Contact Person:          Phone:          Contractor Registration #    Exp.</p>
---	---

Sincerely,

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Office Coordinator -  
 Division File  
 (Rev. - 1/98)