



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 1-041282
Permit # 00789-2008UPG
Request Rec'd 05/16/2008
Amended Date
Approval Date 5/16/2008 JC
Permit Expires 11/16/2008

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Vista Marketing Group P.O. Box 6206 Rockford, IL 61125 Contact: Chip Williams (815) 964-3920	(2) FACILITY - name and address where tanks are located: Vista Shell SW Corner of Perryville Weaver Roads Rockford, Winnebago Co., IL Contact: Chip Williams (815) 964-3920
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) **Number and size of tanks being upgraded or repaired:** (TK # 1) - 15,000 gallons, (TK # 2) - 6,000 gallons
- (b) **Type of tanks:** (TK # 1, 2) - Existing single wall fiberglass
- (c) **Type of piping:** (TK # 1, 2) - (Installing) Ameron Dualoy 3000/LCX double wall fiberglass from the submersible sumps to the new dispenser (this new dispenser area will be where the existing piping from the existing islands will "tie together" with the new piping), (TK # 1, 2) - Existing double wall fiberglass from the new dispenser to the existing dispensers will remain.
- (d) **Product to be stored in each tank:** (TK # 1, 2) - Gasoline
- (e) **Type of leak detection being used:**
 - Tank:** (TK # 1, 2) - Existing automatic tank gauging with CSLD.
 - Piping:** (TK # 1, 2) - Existing interstitial monitoring at both submersible sumps and at all existing dispenser sumps will remain, (TK # 1, 2) - Existing line leak detector, (TK # 1, 2) - (Installing) Veeder Root TLS350 interstitial piping sump sensor at the new dispenser sump only.
- (f) **Corrosion Protection being used:**
 - Tank:** (TK # 1, 2) - Existing fiberglass
 - Piping:** (TK # 1, 2) - Existing fiberglass from new dispenser sump to existing islands will remain, (TK # 1, 2) - (Installing) Fiberglass from the tanks to the new dispenser.
- (g) **Spill containment devices:**
- (h) **Overfill prevention devices:**
- (i) **Manway accessible at grade:**

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Nate Meyer Phone: (815) 398-6250 Contractor Registration # IL-1890 Exp.
--

Sincerely,

