



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 6-000699  
Permit # 00763-2008INS  
Request Rec'd 05/13/2008  
Amended Date  
Approval Date 5/13/2008 JC  
Permit Expires 11/13/2008

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Little Nashville, Inc. 11700 State Route 127, P.O. Box 243 Nashville, IL 62263  Contact: Thomas Gray (618) 478-5777	<b>(2) FACILITY</b> - name and address where tanks are located:  Little Nashville, Inc. 11700 State Route 127, P.O. Box 243 Nashville, Washington Co., IL  Contact: Gray Thomas R (618) 478-5777
--	--

**(3) INSTALLATION OF TANKS:**

- (a) Number and size of tanks being installed:** (TK # 5, 6, 7) - 10,000 gallons, (TK # 8) - 4,000 gallons
- (b) Type of tanks:** (TK # 5, 6, 7, 8) - (Installing) Containment Solutions double wall fiberglass
- (c) Type of piping:** (TK # 5, 6, 7, 8) - (Installing) partial A.O. Smith single wall fiberglass from the new tanks to the existing piping from the original tank system (see site plan - each new section will be less than 20' according to the contractor. If more than 20' sections need to be used, then the entire run will have to be replaced with double wall piping, and interstitial sensors at the tank sumps and dispenser sumps per Feb. 1st, 2008 amended section 170.421 rule), (TK # 5, 6, 7, 8) - Existing single wall fiberglass from the existing dispensers to the new partial sections.
- (d) Product to be stored in each tank:** (TK # 5, 8) - Gasoline, (TK # 6, 7) - Diesel Fuel
- (e) Type of leak detection being used:**
  - Tank:** (TK # 5, 6, 7, 8) - Existing automatic tank gauging with CSLD console to remain. Also the existing probes from the old tanks will be re-used if possible. New probes will be installed if the old ones cannot be re-used., (TK # 5, 6, 7, 8) - (Installing) Veeder Root TLS 350 interstitial tank sensor
  - Piping:** (TK # 5, 6, 7, 8) - (Installing) Red Jacket FX1 mechanical line leak detector
- (f) Corrosion Protection being used:**
  - Tank:** (TK # 5, 6, 7, 8) - (Installing) Fiberglass
  - Piping:** (TK # 5, 6, 7, 8) - (Installing) partial fiberglass (TK # 5, 6, 7, 8) - Existing partial fiberglass
- (g) Spill containment devices:**
- (h) Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) GENERAL REQUIREMENTS:**

**(6) SPECIAL CONTINGENCIES:**

<b>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>          Contact Person: Phone: 812-424-0014  Contractor Registration # IL-2145 Exp.
---

Sincerely,

