



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

<u>FOR OFFICE USE ONLY</u>
Facility # 7-024633
Permit # 00744-2008UPG
Request Rec'd 05/08/2008
Amended Date
Approval Date 5/12/2008 JC
Permit Expires 11/12/2008

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Moto Mart, Inc.        721 West Main Street, P. O. Box 122        Belleville, IL 62222-0122</p> <p>Contact: Joe Hooten (618) 233-6756 Ext.</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>I 57 Motomart        2604 West Main        Marion, Williamson Co., IL</p> <p>Contact: Dan Duncan (618) 233-6754</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 3) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* Contractor is breaking concrete next to the building at the terminal end of the premium vent line to make a repair to it. The line at this point appears to be allowing access for water ingress that is ultimately ending up in the tank. Also, an OPW 233 extractor fitting will be installed on this tank where the premium vent line makes contact with the tank, and an 18" Universal round manhole will be installed around this fitting to allow for the line test on the vent line after the repairs are made.
- (d) *Product to be stored in each tank:* (TK # 3) - Gasoline
- (e) *Type of leak detection being used:*  
     *Tank:*  
     *Piping:*
- (f) *Corrosion Protection being used:*  
     *Tank:*  
     *Piping:*
- (g) *Spill containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p> <p align="right">Contact Person: LaDonna Clymore        Phone: (314) 772-4501        Contractor Registration # IL-1502 Exp.</p>
--

Sincerely,

*James J. Coffey*

