



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 3-043877
Permit # 00708-2008INS
Request Rec'd 05/07/2008
Amended Date
Approval Date 5/7/2008 JC
Permit Expires 11/7/2008

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

| | |
|---|---|
| (1) OWNER OF TANKS - Corporation, partnership, or other business entity: Performance Food Group / TPC P.O. Box 7210 Rock Island, IL 61204 Contact: | (2) FACILITY - name and address where tanks are located: Performance Food Group / TPC 8151 51st West, TPC Road Rock Island, Rock Island Co., IL Contact: |
|---|---|

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed:** (TK # 1) - 12,000 gallons, (TK # 2) - 6,000 gallons
- (b) Type of tanks:** (TK # 1, 2) - (Installing) Glasteel II double wall composite tanks will only partially be buried due to high water table. They will also have a retaining wall around them.
- (c) Type of piping:** (TK # 1, 2) - (Installing) A.P.T. Poly Tech P175 SC double wall flexible product piping from the transition sump to the dispensers. There will be above ground steel piping from the tank submersible pumps to the transition sump where it will connect to the underground fiberglass piping. The remote fill area and the transition sump area will have crash bollards.
- (d) Product to be stored in each tank:** (TK # 1, 2) - Diesel Fuel
- (e) Type of leak detection being used:**
 - Tank:** (TK # 1, 2) - (Installing) Veeder Root TLS 350 Plus Interstitial tank sensor, (TK # 1, 2) - (Installing) Veeder Root TLS 350 Plus Automatic tank gauge with CSLD
 - Piping:** (TK # 1, 2) - (Installing) FE Petro STP-MLD-D mechanical line leak detector, (TK # 1, 2) - (Installing) Veeder Root TLS 350 Plus interstitial piping sump sensors at all dispenser sumps and at the transition sump.
- (f) Corrosion Protection being used:**
 - Tank:** (TK # 1, 2) - (Installing) Composite
 - Piping:** (TK # 1, 2) - (Installing) Non-corrosive flexible
- (g) Spill containment devices:**
- (h) Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**

(5) GENERAL REQUIREMENTS:

(6) SPECIAL CONTINGENCIES:

| |
|--|
| (7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Contact Person: Gary Broshuis Phone: 515-264-4306 Contractor Registration # IL-598 Exp. |
|--|

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File

