

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

Amended and Revised

FOR OFFICE USE ONLY

Facility # 3-044020
Permit # 00616-2008INS
Request Rec'd 04/23/2008
Amended Date 05/01/2008
Approval Date 4/24/2008 JC
Permit Expires 10/24/2008

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Greater Peoria Airport Authority 6100 West Dirksen Parkway Peoria, IL 61607	Rental Car Facility 1501 S. Maxwell Road Peoria, Peoria Co., IL
Contact: Ken Spirito (309) 697-8132	Contact:

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 1) 12,000 gallons
- (b) Type of tanks: (TK # 1) (Installing) Containment Solutions double wall fiberglass brine filled
- (c) Type of piping: (TK # 1) (Installing) Ameron Dualoy 3000/LCX double wall fiberglass
- (d) Product to be stored in each tank: (TK # 1) Gasoline
- (e) Type of leak detection being used:

Tank: (TK # 1) - (Installing) Veeder Root TLS 350 hydrostatic reservoir sensor for tank leak detection, (TK # 1) - (Installing) Veeder Root TLS350 automatic tank gauge for inventory purposes only.

Piping: (TK # 1) - (Installing) Veeder Root TLS350 interstitial piping sump sensors at submersible sump and at all dispenser sumps, (TK # 1) - (Installing) Red Jacket FX1V mechanical line leak detector

(f) Corrosion Protection being used:

Tank: (TK # 1) - (Installing) Fiberglass *Piping:* (TK # 1) - (Installing) Fiberglass

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) GENERAL REQUIREMENTS:
- (6) <u>SPECIAL CONTINGENCIES</u>:

Contact Person:

Janu J Coffey

Phone: (309) 347-1819

Contractor Registration # IL-1293 Exp.

Sincerely,

cc: Storage Tank Safety Specialist -

Fire Department -Office Coordinator -

Division File (Rev. - 1/98)