



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 3-043850
Permit # 00665-2008INS
Request Rec'd 05/01/2008
Amended Date
Approval Date 5/1/2008 DS
Permit Expires 11/1/2008

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Sullivan Foods 425 1st Street, P.O. Box 387 Savanna, IL 61074 Contact: Mike Sullivan (815) 273-4511	(2) FACILITY - name and address where tanks are located: Sullivan Foods 605 Tenney Street Kewanee, Henry Co., IL Contact:
---	--

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed:** (TK # 1) - 15,000 gallons, (TK # 2) - 7,500 gallons
- (b) Type of tanks:** (TK # 1, 2) - (Installing) Double wall composite tank system from re-certified tanks
- (c) Type of piping:** (TK # 1, 2) - Existing steel primary within secondary containment system to be re-installed
- (d) Product to be stored in each tank:** (TK # 1, 2) - Gasoline
- (e) Type of leak detection being used:**
 - Tank:** (TK # 1, 2) - Existing interstitial monitoring to be re-installed, (TK # 1, 2) - Existing automatic tank gauging to be re-installed
 - Piping:** (TK # 1, 2) - Existing line leak detector to be re-installed, (TK # 1, 2) - Existing interstitial monitoring at all submersible sumps and at all dispenser sumps to be re-installed
- (f) Corrosion Protection being used:**
 - Tank:** (TK # 1, 2) - Existing composite
 - Piping:** (TK # 1,2) - Existing secondary containment
- (g) Spill containment devices:**
- (h) Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**

(5) GENERAL REQUIREMENTS:

(6) SPECIAL CONTINGENCIES:

(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Contact Person: Phone: (563) 381-5092 Contractor Registration # IL-345 Exp.

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)