



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 3-008112  
Permit # 00637-2008INS  
Request Rec'd 04/29/2008  
Amended Date  
Approval Date 4/29/2008 JC  
Permit Expires 10/29/2008

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Riverland FS, Inc. 126 Public Square, Box 217, Knoxville, IL 61448  Contact: Dennis Brown (309) 289-2383	<b>(2) FACILITY</b> - name and address where tanks are located:  Riverland FS, Inc. 764 90th Street Roseville, Warren Co., IL  Contact: Nick Dwyer (309) 426-2138
---	---

**(3) INSTALLATION OF TANKS:**

- (a) Number and size of tanks being installed:** One compartment tank consisting of: (TK # 6) - 7,000 gallons, (TK # 7) - 8,000 gallons, and one tank : (TK # 8) - 10,000 gallons
- (b) Type of tanks:** (TK # 6, 7) - (Installing) Containment Solutions double wall fiberglass, (TK # 8) - (Installing) Containment Solutions double wall fiberglass brine filled
- (c) Type of piping:** (TK # 6, 7, 8) - (Installing) Ameron Dualoy 3000/LCX double wall fiberglass
- (d) Product to be stored in each tank:** (TK # 6) - E-85, (TK # 7) - Gasoline, (TK # 8) - Diesel Fuel
- (e) Type of leak detection being used:**
  - Tank:** (TK # 6, 7, 8) - (Installing) Veeder Root TLS 350 with CSLD automatic tank gauge, (TK # 6, 7) - (Installing) Veeder Root TLS 350 interstitial tank sensor, (TK # 8) - (Installing) Veeder Root TLS 350 hydrostatic reservoir sensor
  - Piping:** (TK # 6, 7) - (Installing) Red Jacket FX1V mechanical line leak detector, (TK # 6, 7, 8) - (Installing) Veeder Root TLS350 interstitial piping sump sensors at all dispenser sumps and all submersible sumps, (TK # 8) - (Installing) Red Jacket FX1DV mechanical line leak detector
- (f) Corrosion Protection being used:**
  - Tank:** (TK # 6, 7, 8) - (Installing) Fiberglass
  - Piping:** (TK # 6, 7, 8) - (Installing) Fiberglass
- (g) Spill containment devices:**
- (h) Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) GENERAL REQUIREMENTS:**

**(6) SPECIAL CONTINGENCIES:**

<b>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>          Contact Person: Phone: (309) 347-1819  Contractor Registration # IL-1293 Exp.
---

Sincerely,

