



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

Amended

FOR OFFICE USE ONLY
Facility # 1-035680
Permit # 00282-2008UPG
Request Rec'd 02/27/2008
Amended Date 04/23/2008
Approval Date 2/28/2008 JC
Permit Expires 8/28/2008

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: South Shore Boat Club P.O. Box 124, Peru, IL 61356 Contact: Robert Rowe (815) 223-5343	(2) FACILITY - name and address where tanks are located: South Shore Boat Club 2400 West Water Street Peru, LaSalle Co., IL Contact: Robert Rowe (815) 223-5343
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 2,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1) - (Installing) / replacing approximately 75' section of A.P.T. Poly Tech P175 MD double wall flexible product piping from the existing transition sump (located nearest the retaining wall), to the existing transition sump near the hinged gangplank / piling area (located towards the shore). **The existing piping from the shoreside transition sump to the dock transition sump will remain; however, the contractor will relocate the dock transition sump from under the dock to above the dock. Then, the contractor will replace approximately 10' - 12' of the existing piping from the dock transition sump to the existing dock dispenser with A.P.T. Poly Tech P175 MD double wall flexible.**
- (d) *Product to be stored in each tank:* (TK # 1) - Gasoline
- (e) *Type of leak detection being used:*
Tank:
Piping: (TK # 1) - Existing interstitial monitoring at tank sump, all transition sumps, and at the dispenser pans.
- (f) *Corrosion Protection being used:*
Tank:
Piping:
- (g) *Spill containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Chris Epkins Phone: (309) 347-1819 Contractor Registration # Exp.

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)