



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 5-044012
Permit # 00604-2008INS
Request Rec'd 04/21/2008
Amended Date
Approval Date 4/22/2008 JC
Permit Expires 10/22/2008

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Moto Mart, Inc. 721 West Main Street, P. O. Box 122 Belleville, IL 62222-0122 Contact: Joe Hooten (618) 233-6756 Ext.	(2) FACILITY - name and address where tanks are located: Lincoln Moto Mart 610 South Grand Avenue East Springfield, Sangamon Co., IL Contact:
---	--

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed:** (TK # 1) - 20,000 gallons, (TK # 2, 3) - 10,000 gallons
- (b) Type of tanks:** (TK # 1, 2, 3) - (Installing) Glasteel II double wall composite
- (c) Type of piping:** (TK # 1, 2, 3) - (Installing) OPW Pisces double wall flexible product piping and fiberglass chase piping.
- (d) Product to be stored in each tank:** (TK # 1, 2) - Gasoline, (TK # 3) - Diesel Fuel
- (e) Type of leak detection being used:**
 - Tank:** (TK # 1, 2, 3) - (Installing) Incon TS-550 automatic tank gauge, (TK # 1, 2, 3) - (Installing) Incon TSP-EIS Interstitial tank sensor
 - Piping:** (TK # 1, 2, 3) - (Installing) Incon TS-LLD electronic line leak detector, (TK # 1, 2, 3) - (Installing) Incon TSP ULS Interstitial Sensors at all submersible sumps and all dispenser sumps.
- (f) Corrosion Protection being used:**
 - Tank:** (TK # 1, 2, 3) - (Installing) Composite
 - Piping:** (TK # 1, 2, 3) - (Installing) Fiberglass secondary containment, (TK # 1, 2, 3) - (Installing) Non-corrosive flexible product piping.
- (g) Spill containment devices:**
- (h) Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**

(5) GENERAL REQUIREMENTS:

(6) SPECIAL CONTINGENCIES:

(7) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Greg Spiros Phone: Contractor Registration # IL-1910 Exp. 02/09/2010

Sincerely,

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)