



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-020681
Permit # 00565-2008LIN
Request Rec'd 04/15/2008
Amended Date
Approval Date 4/15/2008 JC
Permit Expires 10/15/2008

Permit for INSPECTION OF INTERIOR LINING of Underground Storage Tank(s) for Petroleum and Hazardous Substances.

Permission to inspect existing interior lining of underground storage tank(s) is hereby granted. Such inspections of interior lining must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code, Part 170. Such inspections of interior lining shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Rock Build Enterprises, Inc. 14123 S. 85th Ave. Orland Park, IL 60462 Contact:	(2) FACILITY - name and address where tanks are located: Marathon 210 E. Hawley Street Mundelein, Lake Co., IL Contact: Imtiaz Syed (847) 949-0860
--	---

(3) INSPECTION OF INTERIOR LINING OF TANKS:

- (a) *Number and size of tanks being inspected:* (TK # 1, 2) - 10,000 gallons, (TK # 3) - 6,000 gallons
- (b) *Type of tanks:*
- (c) *Product stored in each tank:* (TK # 1, 2, 3) - Gasoline
- (d) *Manway accessible at grade:* Contractor did not state whether or not a manway was present or to be installed.

- (4) **Any tank that has been out of service for a twelve-month consecutive period cannot be put back into service unless it meets all new UST upgrade regulations. This permit is for the inspection of the existing interior lining only. No repairing, upgrading, or interior lining is authorized with this permit.**
- (5) **The owner must notify this Office when completion of tank interior inspection has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**
- (6) **SPECIAL CONTINGENCIES:** Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by sections 170.430(a)(1)(C) and (D), 170.430(b)(5), and 170.430(c)(10). Contractor did not state whether or not a manway is present, or to be installed.

(7) PERSON, FIRM OR COMPANY PERFORMING WORK: Chicago Tank Lining, Inc. 600 Hartrey Evanston, IL 60202-1974	Contact Person: Kenneth Brand Phone: Contractor Registration # Exp.
--	--

Sincerely,

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)