



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

**Amended**

FOR OFFICE USE ONLY  
Facility # 2-035697  
Permit # 00500-2008UPG  
Request Rec'd 03/31/2008  
**Amended Date 04/14/2008**  
Approval Date 4/3/2008 JC  
Permit Expires 10/3/2008

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  7-Eleven, Inc. P.O. Box 711, 2711 North Haskell Dallas, TX 75221-0711  Contact: Shane Partridge (972) 828-7450	<b>(2) FACILITY</b> - name and address where tanks are located:  7-Eleven #32202 1202 North Eola Aurora, Kane Co., IL  Contact: Suzanne Schweikart (757) 490-6339 Ext.
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) **Number and size of tanks being upgraded or repaired:** (TK # 1) - 15,000 gallons, (TK # 2, 3) - 10,000 gallons
- (b) **Type of tanks:** (TK # 1, 2, 3) - Existing double wall composite
- (c) **Type of piping: (TK # 1, 2, 3) - (Installing) Fiberglass secondary 4" chase containment,** (TK # 1, 2, 3) - (Installing) OPW Flexworks CP-15 double wall non corrosive flexible to replace the existing primary piping.
- (d) **Product to be stored in each tank:** (TK # 1, 2, 3) - Gasoline
- (e) **Type of leak detection being used:**
  - Tank:** (TK # 1, 2, 3) - Existing automatic tank gauging, (TK # 1, 2, 3) - Existing interstitial monitoring
  - Piping:** (TK # 1, 2, 3) - (Installing) Veeder Root TLS350 interstitial piping sump sensors at all dispenser sumps only., (TK # 1, 2, 3) - Existing interstitial monitoring at each submersible sump to remain
- (f) **Corrosion Protection being used:**
  - Tank:** (TK # 1, 2, 3) - Existing composite
  - Piping:** (TK # 1, 2, 3) - (Installing) Non-corrosive flexible primary piping **and fiberglass secondary chase piping,** (TK # 1, 2, 3) - (Installing) containment sump **at all dispenser sumps** and all submersible sumps
- (g) **Spill containment devices:**
- (h) **Overfill prevention devices:**
- (i) **Manway accessible at grade:**

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	Contact Person: Doug Harmon Phone: (708) 758-3222  Contractor Registration # IL-194 Exp.
---	---

Sincerely,

