



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

**Amended**

FOR OFFICE USE ONLY  
Facility # 3-018768  
Permit # 00463-2008UPG  
Request Rec'd 03/28/2008  
**Amended Date 04/10/2008**  
Approval Date 3/28/2008 JC  
Permit Expires 9/28/2008

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Git-N-Go Convenience Stores, Inc. 2716 Iindanda Avenue Des Moines, IA 50315  Contact: Pete Klindt (515) 288-8565	<b>(2) FACILITY</b> - name and address where tanks are located:  Git N Go #15 1104 42nd Avenue East Moline, Rock Island Co., IL  Contact: Pete Klindt (515) 288-8565
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired:** (TK # 1, 2) - 10,000 gallons
- (b) Type of tanks:** (TK # 1, 2) - Existing single wall steel
- (c) Type of piping:** (TK # 1, 2) - (Installing) A.P.T. Poly Tech P175 SC double wall flexible to replace the existing product piping. New dispensers will also be installed to replace the existing dispensers.
- (d) Product to be stored in each tank:** (TK # 1, 2) - Gasoline
- (e) Type of leak detection being used:**
  - Tank:** (TK # 1, 2) - Existing automatic tank gauging
  - Piping:** (TK # 1, 2) - (Installing) Veeder Root TLS350 interstitial piping sump sensors at all dispenser sumps and all submersible sumps, (TK # 1, 2) - (Installing) Veeder Root TLS350 electronic line leak detector
- (f) Corrosion Protection being used:**
  - Tank:** (TK # 1, 2) - Existing impressed current cathodic protection
  - Piping:** (TK # 1, 2) - (Installing) new containment sumps at the existing submersibles and at the new dispensers, (TK # 1, 2) - (Installing) Non-corrosive flexible
- (g) Spill containment devices:**
- (h) Overfill prevention devices:**
- (i) Manway accessible at grade:**

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>          Contact Person: Mike Worthington Phone: 515-262-5000  Contractor Registration #    Exp.
---

Sincerely,

Jim Coffey

