

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

REVISED

FOR OFFICE USE ONLY

Facility # 4-043921 Permit # 00133-2008INS Request Rec'd 01/15/2008 Amended Date Approval Date 1/28/2008 JC

Permit Expires 7/28/2008

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Reeves Farms LLC 20488 N 1900 East Rd Towanda, IL 61776	Reeves Farms LLC 20488 N. 1900 east Rd. Towanda, McLean Co., IL
Contact:	Contact:

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 1, 2) 10,000 gallons
- (b) Type of tanks: (TK # 1, 2) (Installing) Containment Solutions single wall fiberglass
- (c) Type of piping: (TK # 1, 2) (Installing) Steel, from tank to grade level (see contingencies section).
- (d) Product to be stored in each tank: (TK # 1, 2) Diesel Fuel
- (e) Type of leak detection being used:

Tank: (TK # 1, 2) - (Installing) Veeder Root TLS 300 automatic tank gauge for inventory control and leak detection.

Piping: (TK # 1, 2) - (Installing) European Suction

(f) Corrosion Protection being used:

Tank: (TK # 1, 2) - (Installing) Fiberglass

Piping: (TK # 1, 2) - (Installing) Dielectric coating

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) GENERAL REQUIREMENTS:
- (6) SPECIAL CONTINGENCIES:

<u>M OR COMPANY PERFORMING WOR</u>

Contact Person:

Janu J Coffey

Phone: (309) 347-1819

Contractor Registration # IL-1293 Exp.

Sincerely,

cc: Storage Tank Safety Specialist -

Fire Department -Office Coordinator -

Division File (Rev. - 1/98)