



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

| |
|----------------------------|
| <u>FOR OFFICE USE ONLY</u> |
| Facility # 2-043821 |
| Permit # 00498-2008REM |
| Request Rec'd 03/31/2008 |
| Amended Date |
| Approval Date 4/3/2008 JC |
| Permit Expires 10/3/2008 |

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

| | |
|--|--|
| <p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Harjit Sahi 1217 E. Cambridge Dr. Schererville, IL 46375</p> <p>Contact:</p> | <p>(2) FACILITY - name and address where tanks are located:</p> <p>Raceco 450 Cicero Avenue University Park, Will Co., IL</p> <p>Contact:</p> |
|--|--|

(3) REMOVAL OF TANKS:

- (a) **Number and size of tanks being removed:** (TK # 1, 2) - 20,000 gallons, (TK # 3, 4) - 10,000 gallons
- (b) **Product stored in each tank:** (TK # 1, 2, 3, 4) - Gasoline
- (c) **Reason of tanks being removed:** Tanks floated and have to be re-certified and re-installed. Installation will require new install permit. The tanks will be re-numbered as 7,8,9,10.
- (d) **If tank(s) is leaking, indicate IEMA incident number:**
- (e) **Date each tank was last used:** (TK # 1), (TK # 2), (TK # 3), (TK # 4)

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 170.640 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES: These tanks floated and will have to be removed and re-certified. These tanks are being re-certified. The requirements listed in 170.420 (a) (6) of the Title 41 Illinois Administrative Code must be met for re-certified tanks. Tank Recertification from the manufacturer must be made available to the Storage Tank Safety Specialist.

| | |
|--|---|
| (6) PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| <p>Schmidt Brothers Excavating, Inc. 24222 South Cicero Avenue,</p> | <p>Contact Person: Jim Schmidt Phone: Contractor Registration # Exp.</p> |

Sincerely,

cc: Storage Tank Safety Specialist -
 Fire Department -
 Office Coordinator -
 Division File
 (Rev. - 6/07)