

## OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

**Division of Technical Services** 

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

## FOR OFFICE USE ONLY

Facility # 1-034505 Permit # 00491-2008UPG Request Rec'd 03/31/2008 Amended Date Approval Date 4/2/2008 JC Permit Expires 10/2/2008

## Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Exxon Mobil Oil Corporation 7300 West Friendly Avenue, P.O. Box 22087, CMS Mailstop F-76 Greensboro, NC 27420-2087	Belvidere Oasis Northside Westbound Belvidere Oasis Northside Westbound,5551 Pearl Street, NW Tollway I-90 Milepost 54.7 Belvidere, Boone Co., IL
Contact: Eric McPhee (800) 253-8054	Contact: Jeff Johnson (815) 521-7369

## (3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 21) 15,000 gallons
- (b) Type of tanks: (TK # 21) Existing double wall fiberglass brine filled tank to be repaired by Containment Solutions (interior of tank has a spot that needs to be patched after an inspection was performed by the manufacturer).
- (c) Type of piping:
- (d) Product to be stored in each tank: (TK # 21) Gasoline
- (e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at <a href="https://www.state.il.us/osfm">www.state.il.us/osfm</a> or by calling (217)785-1020.

James of Coffey

(5) **SPECIAL CONTINGENCIES**:

<b>(6)</b>	PERSON.	FIRM OR	COMPANY	PERFORMING	WORK:

Contact Person: Doug Harmon Phone: (708) 758-3222

Contractor Registration # IL-194 Exp.

Sincerely,

cc: Storage Tank Safety Specialist - Fire Department -

Office Coordinator -Division File

(Rev. - 1/98)