



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

FOR OFFICE USE ONLY
 Facility # 4-043622
 Permit # 01332-2012UPG
 Request Rec'd 12/28/2012
 Amended Date
 Approval Date 12/28/2012 JC
Permit Expires 1/14/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

| | |
|--|---|
| <p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Pilot Travel Centers, LLC P.O. Box 10146 Knoxville, TN 37909-3221 Contact: Joey Cupp (800) 562-6210 Ext. 2826</p> | <p>(2) FACILITY - name and address where tanks are located: Pilot Travel Center #368 4030 E. Boyd Road Decatur, Macon Co., IL Contact: Maria Strohl (217) 878-0208</p> |
|--|---|

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired:* (TK # 5) - 20,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* **See the contingencies section for emergency repair details.**

(d) *Product to be stored in each tank:* (TK # 5) - Diesel Fuel

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) **The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

(5) SPECIAL CONTINGENCIES:

| | |
|--|--|
| <p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Saint Louis, MO 63139</p> | <p>Contact Person: Rick McKay Phone: (314) 772-4501 Contractor Registration # IL-1502 Exp.</p> |
|--|--|

Sincerely,

cc: Storage Tank Safety Specialist -
 Fire Department -
 Office Coordinator -
 Division File
 (Rev. - 9/10)