



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2022809
Permit # 00896-2019UPG
Request Rec'd 05/07/2019
Amended Date
Approval Date 5/8/2019 DS
Permit Expires 11/8/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: St. Mary Gas Company 5330 La Grange Countryside, IL 60525 Contact: shibu joseph (630) 673-3382	(2) <u>FACILITY</u> - name and address where tanks are located: St. Mary Gas Company 5330 La Grange Countryside, IL 60525 Contact: Netty Reyes (630) 673-3382
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 7, 8, 9) - 12,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 7, 8, 9) Piping - Fiberglass Double Wall*
- (d) *Product to be stored in each tank: (TK # 7) - Gasoline - Regular, (TK # 8) - Diesel Fuel, (TK # 9) - Gasoline - Premium*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : Cut back existing piping to allow for dispenser sump replacement. All dispensers sumps at this site failed testing and must be replaced. NOVE0020190440. **NOTE: NUPI Poly sumps being installed per contractor**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Cardinal Compliance LLC
730 Creel Dr
Wood Dale, IL 601910000

Contact Person: Chris Derro
Phone: (708) 452-8620
Contractor Registration # IL002418 Exp. 3/18/2021

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File