



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 7035519  
Permit # 00909-2019UPG  
Request Rec'd 05/08/2019  
Amended Date  
Approval Date 5/9/2019 DS  
Permit Expires 11/12/2019

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Casey's Retail Company P.O. Box 3004 Ankeny, IA 50021  Contact: Jill Reams-Widder (515) 965-6238</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Caseys General Stores #1947 100 Highland Avenue Fairfield, IL 62837  Contact: Sherri Hicks (515) 965-6238</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 2) - 10,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 2) Piping - Flex Connector Steel*

(d) *Product to be stored in each tank: (TK # 2) - Diesel Fuel*

(e) *Type of leak detection being used:*

*Tank:*

*Piping:*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containmnt devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : replace the diesel flex connector at the diesel STP and replaced the diesel flex connector under dispenser 1/2. **NOTE: A submersible sump and dispenser sump MUST be installed if not existing per 175.410 c) and e) 2)**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Hinderliter Construction & Maint., Inc.  
3601 North St. Joseph Avenue  
Evansville, IN 47720

Contact Person: Mark Hinderliter  
Phone: (812) 425-4137  
Contractor Registration # IL646 Exp. 4/2/2020

Sincerely,

  
\_\_\_\_\_

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File