



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 3012534
Permit # 00911-2019REM
Request Rec'd 05/09/2019
Amended Date
Approval Date 5/9/2019 DS
Permit Expires 11/12/2019

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Santok, Inc. 3701 Washington Road East Peoria, IL 61611 Contact: Raj Patel (309) 694-7188</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>J & L 66 3701 Washington Road East Peoria, IL 61611 Contact: Raj Patel (309) 694-7188</p>
---	---

(3) **REMOVAL OF PIPING:**

- (a) *Description/location of piping being removed:*
- (b) *Which tank(s) are associated with the piping being removed: (TK # 1, 2) - 10,000, (TK # 3) - 8,000*
- (c) *Reason of piping being removed:*
- (d) *If piping is leaking, indicate IEMA incident number:*

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES** : Removing existing underground product piping and containment sumps due to site upgrade. Existing single wall FRP vent piping to remain.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Total Petroleum Service Company 2421 Washington Road Washington, IL 61571	Contact Person: Greg McCoy Phone: (309) 694-8224 Contractor Registration # IL1079 Exp. 2/8/2020
---	---

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File