



**City of Chicago**  
**Department of Public Health**  
 333 South State Street, Room 200  
 Chicago, IL 60604  
 3127453152

<p><b>FOR OFFICE USE ONLY</b></p> <p>Facility # 2020294          Permit # 00933-2019UPG          Request Rec'd 05/13/2019          Amended Date          Approval Date 5/14/2019          Permit Expires 11/14/2019</p>
---

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Friends Petroleum, Inc.          308 Scotts Court          Bolingbrook, IL 60440          Contact: Tom Simon (847) 609-1884</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Friends Petroleum, Inc.          3047 S. Halsted Street          Chicago, IL 60608          Contact: Das Meleevettil (312) 842-0118</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 6, 7, 8) - 10,000, (TK # 9) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 6, 7) - Gasoline - Regular, (TK # 8) - Gasoline - Premium, (TK # 9) - Ultra Low Sulfur Diesel*
- (e) Type of leak detection being used:*  
*Tank:*  
*Piping:*
- (f) Corrosion Protection being used:*  
*Tank:*  
*Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 6, 7, 8, 9) Spill Contain Device - Single Wall Spill Bucket OPW 1-2200*
- (h) Overfill prevention devices: (TK # 6, 7, 8, 9) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-410C*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Disable ball floats and install OPW overfill prevention drop tubes.

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p> <p>Stenstrom Petroleum Services Group          2422 Center Street          Rockford, IL 61108</p>	<p>Contact Person: Robert Stenstrom          Phone: (815) 398-6250          Contractor Registration # IL1890 Exp. 4/12/2020</p>
--	---

Sincerely,



Chief Engineer-Storage Tank Section

Raul Valdivia

**cc:** Storage Tank Safety Specialist  
Division File