



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2023811
Permit # 01821-2018UPG
Request Rec'd 11/23/2018
Amended Date 05/14/2019 DS
Approval Date 11/26/2018 DS
Permit Expires 5/29/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Naval Station - Great Lakes 605 Clark Avenue Building #221 Great Lakes, IL 600885000 Contact: Harvey Pokorny (847) 774-8221 Ext. 11	(2) <u>FACILITY</u> - name and address where tanks are located: Naval Station - Great Lakes 540 Cluverius Avenue Building #400 Great Lakes, IL 600882801 Contact: Travis Haas, PE (847) 774-8221 Ext. 20
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 46) - 2,500*
 - (b) Type of tanks:*
 - (c) Type of piping: (TK # 46) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L single wall fiberglass VENT piping, (TK # 46) Piping - Fiberglass Double Wall Ameron Dualoy 3000/L supply and return lines from tank to transition sump, (TK # 46) Piping - Other Steel Riser, (TK # 46) Piping - Ball Valves, (TK # 46) Piping - Flex Connector Steel, (TK # 46) Piping - Single Wall STP/Tanktop Sump Bravo B-407-PP, (TK # 46) Piping - Single Wall Transition Sump Bravo B-600 Series*
 - (d) Product to be stored in each tank: (TK # 46) - Diesel Fuel*
 - (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 46) Leak Detect - Piping - Piping Sump Sensors Not Regulated*
 - (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
 - (g) Spill containment devices, piping, and dispenser containment devices: (TK # 46) Spill Contain Device - Single Wall Spill Bucket OPW 1-2100-DEVR*
 - (h) Overfill prevention devices: (TK # 46) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-400C*
 - (i) Manway accessible at grade:*
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Adding new piping to the job

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: (815) 398-6250
Contractor Registration # IL1890 Exp. 4/12/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File