



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 1015018
Permit # 01095-2019UPG
Request Rec'd 06/06/2019
Amended Date
Approval Date 6/6/2019 DS
Permit Expires 12/6/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Shweta 01, Inc. 3742 w. Merrimac Lane Hanover Park, IL 60133 Contact: Bobby (Brijesh) Patel	(2) FACILITY - name and address where tanks are located: Shweta 01, Inc. d/b/a Little Keg 103 Diagonal Street Elizabeth, IL 61028 Contact: Bobby (630) 776-8238
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 8,000, (TK # 2) - 4,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2) Piping - Galvanized Steel Single Wall Piping, (TK # 1, 2) Piping - Partial Fiberglass Double Wall Ameron Dualoy 3000/LCX to accomodate new tank sumps, (TK # 1, 2) Piping - Other Steel Riser, (TK # 1, 2) Piping - Other submersible pump, (TK # 1, 2) Piping - Ball Valves, (TK # 1, 2) Piping - Extractor Fitting Valves, (TK # 1, 2) Piping - Single Wall STP/Tanktop Sump Franklin Fueling Systems 4736 Series Polyethylene*
- (d) *Product to be stored in each tank: (TK # 1) - Gasoline - Regular, (TK # 2) - Gasoline - Premium*
- (e) *Type of leak detection being used:*
 - Tank: (TK # 1, 2) Leak Detect - Tank - Interstitial Monitoring Veeder Root TLS 350*
 - Piping: (TK # 1, 2) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 350 PLLD leak sensors*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2) Spill Contain Device - Double Wall Spill Bucket OPW 1C-3112D Edge*
- (h) *Overfill prevention devices: (TK # 1, 2) Overfill Prev Device - Overfill Drop Tube Valve OPW 61SOP*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : Upgrade do to Tank Tech work- Replace STP sumps, install new stp's and all single wall galv STP take offs with new ball valves. Replace vent extractor valves and all tank risers. Install new OPW edge double wall buckets and OPW poppeted coaxial drop tubes. Upgrade tank monitor to PLLD electronic line leak detection and install tank interstitial sensor per Tank Tech.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Seneca Companies, Inc.
4140 East 14th Street PO Box 3360
Des Moines, IA 50313

Contact Person: Glen Davis
Phone: (816) 761-1270
Contractor Registration # IL598 Exp. 2/23/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File