



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**Amended**

**FOR OFFICE USE ONLY**

Facility # 2036543  
Permit # 00746-2019UPG  
Request Rec'd 04/15/2019  
Amended Date 06/11/2019 DS  
Approval Date 4/17/2019 DS  
Permit Expires 10/17/2019

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>CarMax Auto Super Stores, Inc. 12800 Tuckahoe Creek Parkway Richmond, VA 23238</p> <p>Contact: Ali Woodworth (804) 747-0422 Ext. 6293</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>CarMax #7128 250 East Golf Road Schaumburg IL 60173</p> <p>Contact: Mike Rizzi (847) 839-8000 Ext. 4000</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

*(a) Number and size of tanks being upgraded or repaired: (TK # 1) - 10,000*

*(b) Type of tanks:*

*(c) Type of piping: (TK # 1) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX from existing tank to dispenser as shown in site drawing, (TK # 1) Piping - Other submersible pump, (TK # 1) Piping - Ball Valves, (TK # 1) Piping - Positive Shutoff Valves, (TK # 1) Piping - Shear Valves, (TK # 1) Piping - Flex Connector Steel, (TK # 1) Piping - Single Wall STP/Tanktop Sump Bravo B-407-RB*

*(d) Product to be stored in each tank: (TK # 1) - Gasoline - Regular*

*(e) Type of leak detection being used:*

*Tank:*

*Piping: (TK # 1) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring Veeder Root (TK # 1) Leak Detect - Piping - Stand Alone Sensor Interstitial Monitoring Franklin Fueling Systems DC 404 stand alone sump sensor NOTE: Sensors must shut down the submersible pump upon detection of a leak per 175.640 a) 1)*

*(f) Corrosion Protection being used:*

*Tank:*

*Piping:*

*(g) Spill containment devices, piping, and dispenser containmnt devices:*

*(h) Overfill prevention devices:*

*(i) Manway accessible at grade:*

**(4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Need to add stand alone sensors in order to meet postive shut down requirement


Permit is being revised to request that the dispenser be moved 8" further away from the building to adhere to the 10' rule that went into effect on 10/13/2018 per 175.450 f) 5). If the 10' rule cannot be met the contractor must request a waiver.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Stenstrom Petroleum Services Group  
2422 Center Street  
Rockford, IL 61108

Contact Person: Robert Stenstrom  
Phone: (815) 398-6250  
Contractor Registration # IL1890 Exp. 4/12/2020

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File