



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2000751
Permit # 01135-2019UPG
Request Rec'd 06/12/2019
Amended Date
Approval Date 6/12/2019 DS
Permit Expires 12/12/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>ENAR, Inc. 3501 South Central Avenue Cicero, IL 60650 Contact: John Harrah (708) 863-4877</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>35th & Central Citgo 3501 S. Central Ave. Cicero, IL 60650 Contact: Mohammed Rafat (708) 863-4877</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 2) - 3,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 2) Piping - Other submersible pump*

(d) *Product to be stored in each tank: (TK # 2) - Gasoline*

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 2) Spill Contain Device - Single Wall Spill Bucket OPW 1-2100*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Change fees Petro new sumerge pump spill containment electric interbuth and piping new riser for sumerge pump. **NOTES: A submersible sump must be installed if one doesn't already exist per 175.610 b) and the contractor submitted for an emergency repair request to do this work but this does not fall under an emergency**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

CAT Builders USA, Inc.

Contact Person: Jon Kopytek

522 E. Dundee Road
Palatine, IL 60074

Phone: (630) 670-6280
Contractor Registration # IL002381 Exp. 3/12/2020

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File