



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 6021649
Permit # 01136-2019UPG
Request Rec'd 06/12/2019
Amended Date
Approval Date 6/12/2019 DS
Permit Expires 12/12/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>BKB Fuels, Inc. P.O. Box 1263 Bloomington, IL 61702</p> <p>Contact: Hardeep Bhalla (630) 673-7625</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>BKB Fuels, Inc. 409 East Missouri Sandoval, IL 62882</p> <p>Contact: Hardeep Bhalla (630) 673-7625</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 3, 4) - 10,000, (TK # 5) - 12,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 4) Piping - Fiberglass Double Wall Ameron Dualoy 3000/L, (TK # 4) Piping - Ball Valves, (TK # 4) Piping - Flex Connector Steel, (TK # 4) Piping - Single Wall STP/Tanktop Sump Franklin Fueling Systems 4736 Series Polyethylene*
- (d) *Product to be stored in each tank: (TK # 3, 4) - Gasoline, (TK # 5) - Diesel Fuel*
- (e) *Type of leak detection being used:*
Tank:
Piping: (TK # 4) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection Red Jacket FXIV, (TK # 4) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring Veeder Root, (TK # 5) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection Red Jacket FX1DV
- (f) *Corrosion Protection being used:*
Tank:
Piping:
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices: (TK # 3) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-410C*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Tank ID #3 & #4 Installing new OPW Straight Drop Tubes **All three ball float vent valves where check & passed**
 Tank # 5 Installing a Red Jacket FX1DV Diesel Mechanical line leak detector
 Tank #4 Premium Installing a new Franklin Fueling 4736-WT Poly Tank sump w/ new FE Petro 1.5 hp submerg pump , Red Jacket FX1V Mechanical line leak detector, new flex connector, ball valve, Veeder


Root (794380-208) Non- Discriminating sump sensor & partial Ameron 3" over 2" DW FRP piping back into the new tank sump.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Seneca Companies, Inc.
4140 East 14th Street PO Box 3360
Des Moines, IA 50313

Contact Person: Glen Davis
Phone: (816) 761-1270
Contractor Registration # IL598 Exp. 2/23/2020

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File