



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 6000120
Permit # 01162-2019UPG
Request Rec'd 06/18/2019
Amended Date
Approval Date 6/18/2019 DS
Permit Expires 12/18/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>SRP CAP, Corporation 1810 Partridge Place Edwardsville, IL 62025</p> <p>Contact: Cindy Bowling (618) 656-7765</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Four-O Quick Shop 804 S. Main St. Troy, IL 62294</p> <p>Contact: Cindy Bowling (618) 667-9514</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 4) - 12,000, (TK # 5) - 4,000, (TK # 6) - 8,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 4) - Gasoline - Regular, (TK # 5) - Gasoline - Premium, (TK # 6) - Diesel Fuel*
- (e) Type of leak detection being used:*

Tank: (TK # 4, 5, 6) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD

Piping:
- (f) Corrosion Protection being used:*

Tank:


Piping:
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : A TCP//IP NETWORK CARD WAS INSTALLED BY NEUMAYER SOMETIME IN THE PAST YEAR BUT NO UPG PERMIT WAS FILLED. THIS PERMIT IS TO SERVICE AS A THIRD PARTY INSPECTION OF THE EQUIPMENT INSTALLED AND AS AN OPPORTUNITY TO FILE THE NECESSARY PERMIT DOCUMENTATION.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Superior Acquisition LLC d/b/a Superior Equipment Company 7525-A Sussex</p>	<p>Contact Person: Angela Hapgood Phone: (314) 644-6000</p>

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File