



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 2026245
Permit # 01181-2019REM
Request Rec'd 05/16/2019
Amended Date
Approval Date 6/24/2019 DS
Permit Expires 12/24/2019

**Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Graham C-Stores Co. 33978 N. US Hwy 45 P.O Box 89 Gages Lake, IL 600300089  Contact: Mike Graham (847) 254-7605</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Crestwood BP 13459 S. Cicero Avenue Crestwood, IL 60445  Contact: Jack Graham (847) 223-3710</p>
---	--

**(3) REMOVAL OF PIPING:**

- (a) Description/location of piping being removed:*
- (b) Which tank(s) are associated with the piping being removed: (TK # 9) - 20,000, (TK # 10) - 15,000*
- (c) Reason of piping being removed:*
- (d) If piping is leaking, indicate IEMA incident number:*

**(4)** After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

**(5) SPECIAL CONTINGENCIES :** Removing all Environ piping to allow for new piping upgrade.

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Performance Tank, Inc. 730 Creel Drive Wood Dale, IL 60191	Contact Person: Tim Berg Phone: (630) 860-9500 Contractor Registration # IL881 Exp. 1/22/2021

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File