



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

<p align="center">FOR OFFICE USE ONLY</p> <p>Facility # 2013100 Permit # 01205-2019UPG Request Rec'd 06/24/2019 Amended Date 06/25/2019 DS Approval Date 6/25/2019 DS Permit Expires 12/26/2019</p>
--

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>479 Enterprises, Inc. 19N479 Rt. 20 Hampshire, IL 60140 Contact: Perveen Akhtar (630) 788-6532</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Arrowhead Citgo 19N479 Rt. 20 Hampshire, IL 60140 Contact: Ismail Mohammed (630) 788-6532</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 7) - 20,000, (TK # 8, 9) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 7) - Diesel Fuel, (TK # 8) - Gasoline - Regular, (TK # 9) - Gasoline - Premium*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices: (TK # 7, 8, 9) Overfill Prev Device - Ball Only Removed Ball Float Vent Valve*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

I need to amend this permit to reflect that we were not installing a new overfill alarm system for tanks 7, 8 & 9. We only wanted to obtain permit to remove ball floats if they existed on the tanks. The tanks currently have a Veeder Root TLS 350 alarm system.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Southern Tank Midwest
2496 Technology Dr
Elgin, IL 60124

Contact Person: William Umphrey
Phone: (847) 868-3333
Contractor Registration # IL002431 Exp. 9/20/2020

Sincerely,

Daniel H. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File