



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 5036416
Permit # 00576-2019UPG
Request Rec'd 03/27/2019
Amended Date 06/26/2019 DS
Approval Date 3/27/2019 DS
Permit Expires 9/27/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>E & Q LLC 2026 Republic P.O. Box 4307 Springfield, IL 62702</p> <p>Contact: Heather Hoffman (217) 523-5050</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Qik-N-EZ 1230 Toronto Road Springfield, IL 62707</p> <p>Contact: Heather Hoffman (217) 523-5050 Ext. 718</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 2) - 6,000, (TK # 3) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 2) - Gasoline, (TK # 3) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices: (TK # 2, 3) Overfill Prev Device - Overfill Drop Tube Valve Franklin Fueling Systems 708 Defender Series*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Extra tanks was added to this permit and not needed because the ball floats were able to be tested and passed, see below note.

My office guy put down the wrong tanks for the permit, 1,2,3,5, when what I failed was 2,3,4,5. Tank #1 previously passed. During re-inspection, I was able to remove and test the ball floats on tank #4, and #5, so my permit was only needed for #2, and #3.

During annual inspection, the triennial inspection of the ball float vents failed because they could not be removed for this inspection. they will be replaced with drop tube/valves on these tanks.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

W J Scott Company
3861 Tozer Road
Springfield, IL 62707

Contact Person: Jim Scott
Phone: (217) 787-6081
Contractor Registration # IL1949 Exp. 4/18/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File