



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2046885
Permit # 01235-2019REM
Request Rec'd 06/27/2019
Amended Date
Approval Date 6/27/2019 DS
Permit Expires 12/27/2019

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Village of Franklin Park 9500 Belmont Avenue Franklin Park, IL 60131</p> <p>Contact: Rich Pina (847) 671-8252</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Franklin Park Police Station 9545 Belmont Ave Franklin Park, IL 60131</p> <p>Contact: Jim Post (847) 260-5809</p>
--	--

(3) REMOVAL OF TANKS:

- (a) Number and size of tanks being removed: (TK # 1) - 500*
- (b) Description/location of piping being removed:*
- (c) Product to be stored in each tank: (TK # 1) - Heating Oil*
- (d) Reason of tanks being removed:*
- (e) If tank(s) is leaking, indicate IEMA incident number:*
- (f) Date each tank was last used: (TK # 1) - 12/31/1973*

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES : A 500 gallon UST was discovered while performing the demolition of the former Franklin Park Police Sation. The Village of Franklin Park has contracted Environmental Cleansing Corporation to perform the removal of this pre-1974 heating oil tank.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Environmental Cleansing Corporation
16602 South Crawford Avenue
Markham, IL 60428

Contact Person: David Konopko
Phone: (708) 532-7000
Contractor Registration # IL1932 Exp. 12/26/2020

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File