



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Extended

FOR OFFICE USE ONLY

Facility # 2014395
Permit # 00020-2019UPG
Request Rec'd 12/28/2018
Amended Date
Approval Date 1/2/2019 DS
Permit Expires 1/2/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Old Dominion Freight Line, Inc. 500 Old Dominion Way Thomasville, NC 27360</p> <p>Contact: Robert Alexander (336) 822-5571</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Old Dominion Freight Line, Inc. 5500 W. 47th Street Forest View, IL 60638</p> <p>Contact: Tim Carberry (708) 594-3646</p>
--	---

(3) **UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 5) - 20,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 5) Piping - Flexible Double Wall NUPI Smartflex, (TK # 5) Piping - Ball Valves, (TK # 5) Piping - Valves Foot Valve, (TK # 5) Piping - Single Wall Submersible (STP) Sump OPW Fiberglass, (TK # 5) Piping - Single Wall Transition Sump OPW PSTF-4000 Series*

(d) *Product to be stored in each tank: (TK # 5) - Diesel Fuel*

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 5) Leak Detect - Piping - American with Sensors/No Test Suction, (TK # 5) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring Veeder Root

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 5) Spill Contain Device - Field Constructed OPW 211*

(h) *Overfill prevention devices: (TK # 5) Overfill Prev Device - Overfill Drop Tube Valve OPW 61SOR*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES :**

- **-Breaking out and removing concrete as needed for fuel polisher and remote fill piping**
- **-Break out and remove concrete as needed for new sump installs**
- **-Install three tank sumps and one transition sump**
- **-Install 2" double wall NUPI piping for supply and return piping**
- **-Install 3" double wall NUPI remote fill piping**


- -Supply and install two crash protection bollards
- -Backfill and resurface after all underground work is done
- -Install fuel polisher
- -Install new remote fill box
- -Install all necessary above ground piping
- -Paint piping
- -Start up fuel polisher and check for proper operation

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: (815) 398-6250
Contractor Registration # IL1890 Exp. 4/12/2020

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File