



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2014723  
Permit # 01293-2019UPG  
Request Rec'd 07/10/2019  
Amended Date  
Approval Date 7/10/2019 DS  
Permit Expires 1/10/2020

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

|                                                                                                                                                                                                                              |                                                                                                                                                                                                              |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Safa Enterprises, Inc.<br/>4601 S. Harlem Ave.<br/>Forest View, IL 60402</p> <p>Contact: Mohammed Yaqoob (847) 679-5398</p> | <p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Safa Enterprises, Inc.<br/>4601 S. Harlem Ave.<br/>Forest View, IL 60402</p> <p>Contact: Mohammed Yaqoob (847) 679-5398</p> |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**(3) UPGRADE OR REPAIR OF TANKS:**

*(a) Number and size of tanks being upgraded or repaired: (TK # 9, 10, 11) - 12,000*

*(b) Type of tanks:*

*(c) Type of piping:*

*(d) Product to be stored in each tank: (TK # 9, 10, 11) - Gasoline*

*(e) Type of leak detection being used:*

*Tank: (TK # 9, 10, 11) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350*

*Piping:*

*(f) Corrosion Protection being used:*

*Tank:*

*Piping:*

*(g) Spill containment devices, piping, and dispenser containment devices:*

*(h) Overfill prevention devices:*

*(i) Manway accessible at grade:*

**(4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES** : Removing ATG during station remodel and reinstalling in new location upon remodel completion.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

B & K Equipment Company  
2939 175th Street  
Lansing, IL 60438

Contact Person: Ed Angell  
Phone: (708) 474-3344  
Contractor Registration # IL1207 Exp. 2/14/2020

Sincerely,

  

---

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File