



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2007979
Permit # 01295-2019REM
Request Rec'd 07/10/2019
Amended Date
Approval Date 7/10/2019 DS
Permit Expires 1/10/2020

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>I-55 Truckstop Properties LLC 510 S. Bolingbrook Drive Bolingbrook, IL 60440</p> <p>Contact: John Puthusseril (630) 739-7006</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Greater Chicago Truck Plaza 510 South Bolingbrook Drive Bolingbrook, IL 60440</p> <p>Contact: Jeremy Smith (630) 739-7006</p>
---	--

(3) **REMOVAL OF PIPING:**

- (a) *Description/location of piping being removed:*
- (b) *Which tank(s) are associated with the piping being removed: (TK # 13, 14) - 20,000, (TK # 17) - 12,000*
- (c) *Reason of piping being removed:*
- (d) *If piping is leaking, indicate IEMA incident number:*

- (4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

- (5) **SPECIAL CONTINGENCIES** : removing piping for dispensers 5,6,7,8,9 and 10

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9 Aurora, IL 60504	Contact Person: Kiran Patibandla Phone: (630) 649-8699 Contractor Registration # IL002420 Exp. 5/22/2021
--	--

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File