



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2024763
Permit # 01320-2019UPG
Request Rec'd 07/12/2019
Amended Date
Approval Date 7/15/2019 DS
Permit Expires 1/15/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Johnsburg School District 12 2117 West Church Street McHenry, IL 60050 Contact: Robbin Pierce (815) 385-5767	(2) <u>FACILITY</u> - name and address where tanks are located: Johnsburg High School 2002 West Ringwood Road McHenry, IL 60050 Contact: Robbin Pierce (815) 385-5767
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 4) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 4) Piping - Fiberglass Single Wall Piping A.O. Smith from existing tank to existing dispenser. NOTE: Single wall piping may be installed for European suction, per 175.420 b)*
- (d) *Product to be stored in each tank: (TK # 4) - Diesel Fuel*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


- (5) **SPECIAL CONTINGENCIES** : Replacing existing 2" Smith fiberglass single wall piping with new 2" Smith fiberglass single wall piping, extractable suction stub, and new Bravo fiberglass dispenser sump for Gas Boy Atlas suction pump. Existing and new piping European suction. Permit for piping removal applied for. Installing new 10' x 3' island form with U shape bollards at each end of island. Sump to be hydro tested, and product line to be air tested (inspection).

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Howard Lee & Sons Inc.
4093 Perryville Road PO Box 446
Cherry Valley, IL 61016

Contact Person: Vicky Buhl
Phone: (815) 332-4966
Contractor Registration # IL456 Exp. 3/20/2020

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File