



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

Permit for Emergency Repair Request on 6/11/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 17- issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>2 James, LLC 5850 Hwy 145 Harrisburg IL 62946 Contact: Mike Duncan (618) 694-9060</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Mitchellville Country Store 5850 Highway 145 South Harrisburg IL 62946 Contact: Mike Duncan (618) 252-6414</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 5) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 5) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 5) - Gasoline - Regular*
- (e) Type of leak detection being used:*
 Tank:
 Piping:
- (f) Corrosion Protection being used:*
 Tank:
 Piping:
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank For required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Replaced the Unlead flex connector on #3/4 dispenser and all tested OK.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Mid-South Steel Products, Inc.

Contact Person: Billy Thorne

2071 Corporate Circle Drive PO Box 277
Cape Girardeau, MO 63703

Phone: (573) 335-5529
Contractor Registration # IL1194 Exp. 8/16/2020

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File