



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 5017395
Permit # 01335-2019UPG
Request Rec'd 07/16/2019
Amended Date
Approval Date 7/16/2019 DS
Permit Expires 1/16/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Cather Grocery, Inc. 1302 5th Street Lincoln, IL 62656 Contact: Cliff McCumber (217) 735-1123	(2) <u>FACILITY</u> - name and address where tanks are located: 5th Street Food Mart 1302 5th Street Lincoln, IL 62656 Contact: Judy McCumber (217) 735-1123
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 4, 5) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 4, 5) Piping - Flexible Double Wall A.P.T. Poly Tech S175SC, (TK # 4, 5) Piping - Single Wall STP/Tanktop Sump Franklin Fueling Systems A4236-0/0-OB-S*
- (d) *Product to be stored in each tank: (TK # 4) - Gasoline - Regular, (TK # 5) - Gasoline - Premium*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 4, 5) Spill Contain Device - Single Wall Spill Bucket OPW 1-2100C DEVR*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : Replacing both STP sumps, and spill buckets. removing piping from chase to 2 dispensers. pulling in new OPW 1.5" piping through existing chase **NOTE: A removal permit must be submitted for the piping per 175.300 k) 3)**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Seneca Companies, Inc.

Contact Person: Glen Davis

4140 East 14th Street PO Box 3360
Des Moines, IA 50313

Phone: (816) 761-1270
Contractor Registration # IL598 Exp. 2/23/2020

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File