



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

<p align="center">FOR OFFICE USE ONLY</p> <p>Facility # 2036254 Permit # 01129-2019UPG Request Rec'd 06/07/2019 Amended Date 07/22/2019 DS Approval Date 6/12/2019 DS Permit Expires 12/12/2019</p>
--

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>CarMax Auto Super Stores, Inc. 12800 Tuckahoe Creek Parkway Richmond, VA 23238</p> <p>Contact: Ali Woodworth (804) 747-0422 Ext. 6293</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>CarMax #7146 101 North Wolf Road Hillside, IL 60162</p> <p>Contact: Angel or Eddie (708) 449-5200 Ext. 4000</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX from existing tank to existing dispenser as shown in site drawing, (TK # 1) Piping - Other Steel Riser, (TK # 1) Piping - Other submersible pump, (TK # 1) Piping - Ball Valves, (TK # 1) Piping - Positive Shutoff Valves, (TK # 1) Piping - Shear Valves, (TK # 1) Piping - Flex Connector Steel, (TK # 1) Piping - Single Wall STP/Tanktop Sump Bravo B-407-RB*
- (d) *Product to be stored in each tank: (TK # 1) - Gasoline - Regular*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 1) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection FE Petro STP-MLD, (TK # 1) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring Veeder Root in submersible sump, (TK # 1) Leak Detect - Piping - Stand Alone Sensor Interstitial Monitoring Franklin Fueling Systems DC 404 stand alone sump sensor in dispenser sump. NOTE: Sensors MUST shut down the submersible pump upon detection of a leak per 175.640 a) 1)*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 1) Spill Contain Device - Single Wall Spill Bucket OPW 1-2100-DEVR*
- (h) *Overfill prevention devices: (TK # 1) Overfill Prev Device - Overfill Drop Tube Valve OPW 61SOP*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

- Install new Bravo single wall UDC


- Install new single wall Bravo tank top piping sump
 - Install new 2" Ameron LCX double wall product piping
 - Install positive shut down
 - Install new Veeder Root sump sensor in new UDC
 - Install new fill, probe and interstice risers
 - Install new FE Petro submersible pump with mechanical leak detector
 - Install new flex connectors in tank sump and UDC
 - Install new OPW 1-2100 single wall spill bucket
 - Install new OPW 61SOP overfill drop tube
 - Install Franklin Fueling stand alone sump sensors in tank and dispenser sumps to meet positive shut down requirement
 - **NOTE: Dispenser doesn't meet the full 10' clearance required but it is being allowed since it is existing**
- Installing stand alone Franklin fueling sensors in order to meet positive shut down requirements**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: (815) 398-6250
Contractor Registration # IL1890 Exp. 4/12/2020

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File