



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2007979
Permit # 01374-2019UPG
Request Rec'd 07/03/2019
Amended Date
Approval Date 7/23/2019 DS
Permit Expires 1/23/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>I-55 Truckstop Properties LLC 510 S. Bolingbrook Drive Bolingbrook, IL 60440</p> <p>Contact: John Puthusseril (630) 739-7006</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Greater Chicago Truck Plaza 510 South Bolingbrook Drive Bolingbrook, IL 60440</p> <p>Contact: Jeremy Smith (630) 739-7006</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 13, 14) - 20,000, (TK # 17) - 12,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 13, 14, 17) Piping - Flexible Double Wall A.P.T. Poly Tech P175SC from existing tanks to new dispensers as shown in site plan, (TK # 13, 14, 17) Piping - Chase Secondary Containment A.P.T. Poly Tech DCT-400, (TK # 13, 14, 17) Piping - Ball Valves, (TK # 13, 14, 17) Piping - Shear Valves, (TK # 13, 14, 17) Piping - Flex Connector Steel, (TK # 13, 14, 17) Piping - Single Wall STP/Tanktop Sump Petroleum Containment Inc. 4200 Series*

(d) *Product to be stored in each tank: (TK # 13, 14) - Diesel Fuel, (TK # 17) - Bio-Diesel*

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 13, 14, 17) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection Red Jacket FX1, (TK # 13, 14, 17) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring Veeder Root in all submersible and dispenser sumps. NOTE: Sensors must shut down the submersible pump supplying that line upon detection of a leak per 175.640 a) 1)

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 13, 14, 17) Spill Contain Device - Double Wall Spill Bucket OPW 1C-3112D Edge*

(h) *Overfill prevention devices: (TK # 13, 14, 17) Overfill Prev Device - Overfill Drop Tube Valve OPW 7ISO-4010*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : we are installing new piping,new dispenser sumps and new island forms for dispensers. **NOTE: Existing piping to be removed under permit 01295-2019REM**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

America Petropump Services LLC d/b/a Ampsco Services
4075 Fox Valley Center Dr., Unit 9
Aurora, IL 60504

Contact Person: Kiran Patibandla
Phone: (630) 649-8699
Contractor Registration # IL002420 Exp. 5/22/2021

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File