



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 4003560  
Permit # 01400-2019REM  
Request Rec'd 07/26/2019  
Amended Date  
Approval Date 7/29/2019 DS  
Permit Expires 1/29/2020

**Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Mahomet Seymour School District #3 1301 S. Bulldog Dr. PO Box 229 Mahomet, IL 61853</p> <p>Contact: Jeremy Roark (217) 586-5544</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Bus Garage 306 North Division St. Mahomet, IL 61853</p> <p>Contact: Jeremy Roark (217) 586-5544</p>
--	--

(3) **REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed: (TK # 1) - 1,000, (TK # 2) - 2,000*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 1) - Gasoline - Regular, (TK # 2) - Diesel Fuel*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number: 2019-0764*
- (f) *Date each tank was last used: (TK # 1, 2) - Unknown*

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES** : remove tanks and piping for tanks 1 and 2. Tank 3 previously abandoned and to remain as it is in a different location away from tanks 1 and 2. **NOTE: Pertaining to tank #3 it may remain abandoned as long as the reasoning for the abandonment still remains in accordance to our rules, section 175.840 e)** When a UST is allowed to be abandoned-in-place, as specified in this Section, the abandoned-in-place UST shall be removed when the condition for issuing the abandonment permit no longer exists. The removal procedures shall be followed and a removal permit is required.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

RCRA, Inc. d/b/a Earth Services  
10903 Prestwick Drive  
Benton, IL 62812

Contact Person: Josh Appleton  
Phone: (618) 218-4958  
Contractor Registration # IL002364 Exp. 8/7/2019

Sincerely,

Daniel Starks

