



City of Chicago  
Department of Public Health  
333 South State Street, Room 200  
Chicago, IL 60604  
3127453152

**FOR OFFICE USE ONLY**

Facility # 2021822  
Permit # 01426-2019UPG  
Request Rec'd 07/26/2019  
Amended Date  
Approval Date 7/31/2019  
Permit Expires 8/13/2019

**Permit for Emergency Repair Request on 7/25/2019**

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Global Gas for Less 340 Jackson Ave. Glencoe, IL 60022</p> <p>Contact: AKHTAR RAJA (312) 666-2421</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Ashland Gas &amp; Mini Mart/Marathon 649 N. Ashland Chicago, IL 60618</p> <p>Contact: Leo Manaois (312) 666-2421</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

*(a) Number and size of tanks being upgraded or repaired: (TK # 1) - 8,000*

*(b) Type of tanks:*

*(c) Type of piping: (TK # 1) Piping - Flex Connector Steel*

*(d) Product to be stored in each tank: (TK # 1) - Gasoline*

*(e) Type of leak detection being used:*

*Tank:*

*Piping:*

*(f) Corrosion Protection being used:*

*Tank:*

*Piping:*

*(g) Spill containment devices, piping, and dispenser containment devices:*

*(h) Overfill prevention devices:*

*(i) Manway accessible at grade:*

**(4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Anderson Pump Service, Inc.  
19659 South 97th Avenue  
Mokena, IL 60448

Contact Person: Ron Anderson  
Phone: (708) 478-6190  
Contractor Registration # IL002275 Exp. 5/21/2020

Sincerely,



Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist  
Division File