



Office of the Illinois State Fire Marshal  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 2177851020

**FOR OFFICE USE ONLY**  
 Facility # 2046622  
 Permit # 01440-2019UPG  
 Request Rec'd 08/01/2019  
 Amended Date  
 Approval Date 8/1/2019 DS  
 Permit Expires 8/13/2019

**Permit for Emergency Repair Request on 7/1/2019**

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Lenny's Gas N Wash Sauk Trail, LLC        8200 185th St., Unit K        Tinley Park, IL 60487        Contact: (708) 805-2525</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Lenny's Gas N Wash Sauk Trail, LLC        1445 E. Sauk Trail        Sauk Village, IL 60411        Contact: Len McEnery (708) 805-2525</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**


- (a) *Number and size of tanks being upgraded or repaired: (TK # 3) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 3) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 3) - E-85*
- (e) *Type of leak detection being used:*  
     *Tank:*  
     *Piping:*
- (f) *Corrosion Protection being used:*  
     *Tank:*  
     *Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Replaced bad o-ring on flex connector. **NOTE: A sump must be installed under a separate upgrade permit if one does not already exist per section 175.410**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p>	
<p>Anderson Pump Service, Inc.        19659 South 97th Avenue        Mokena, IL 60448</p>	<p>Contact Person: Ron Anderson        Phone: (708) 478-6190        Contractor Registration # IL002275 Exp. 5/21/2020</p>

Sincerely,

---

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File