



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2039896  
Permit # 01471-2019UPG  
Request Rec'd 08/05/2019  
Amended Date  
Approval Date 8/6/2019 DS  
Permit Expires 2/6/2020

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>RDK Ventures, LLC 550 Warrenville Rd., Suite 400 Lisle, IL 60532</p> <p>Contact: Charlene Troyer (630) 800-6065</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Circle K #6824 475 N. Nelson Rd. New Lenox, IL 60451</p> <p>Contact: Jason Hughes (812) 379-9227</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 15,000, (TK # 2) - 10,000, (TK # 3) - 5,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2, 3) Piping - Flexible Double Wall OPW Flexworks from existing tanks to new dispensers as shown in site plan, (TK # 1, 2, 3) Piping - Other Steel Riser, (TK # 1, 2, 3) Piping - Chase Secondary Containment OPW AXP - 4" secondary chase piping, (TK # 1, 2, 3) Piping - Ball Valves, (TK # 1, 2, 3) Piping - Shear Valves, (TK # 1, 2, 3) Piping - Flex Connector Steel, (TK # 1, 2, 3) Piping - Single Wall STP/Tanktop Sump Bravo B-407-PP*
- (d) *Product to be stored in each tank: (TK # 1) - Gasoline - Regular, (TK # 2) - Gasoline - Premium, (TK # 3) - Diesel Fuel*
- (e) *Type of leak detection being used:*
- Tank:*
- Piping:*
- (f) *Corrosion Protection being used:*
- Tank:*
- Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices: (TK # 1, 2, 3) Spill Contain Device - Double Wall Spill Bucket Emco Wheaton A1004*
- (h) *Overfill prevention devices: (TK # 1, 2, 3) Overfill Prev Device - Ball Only Removed Ball Float Vent Valve, (TK # 1, 2, 3) Overfill Prev Device - Overfill Drop Tube Valve Emco Wheaton A1100 Guardian*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.


- (5) **SPECIAL CONTINGENCIES** : Installing new piping and containment sumps. Dispenser sumps to be Bravo B1000 fiberglass sumps. **NOTE: Sensors are existing as well as tank and piping leak detection.**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Anderson Pump Service, Inc.  
19659 South 97th Avenue  
Mokena, IL 60448

Contact Person: Ron Anderson  
Phone: (708) 478-6190  
Contractor Registration # IL002275 Exp. 5/21/2020

Sincerely,



Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File