



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2000803
Permit # 01481-2019INS
Request Rec'd 08/07/2019
Amended Date
Approval Date 8/7/2019 DS
Permit Expires 2/7/2020

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>7-Eleven, Inc. 3200 Hackberry Road - Gas Compliance Irving, TX 75063</p> <p>Contact: Scott Thomas Johnson (815) 307-5432</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>7-Eleven #26063 7749 West Roosevelt Road Forest Park, IL 60130</p> <p>Contact: Scott Thomas Johnson (847) 608-1136</p>
---	---

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 4) - 15,000, (TK # 5) - 7,000, (TK # 6) - 8,000*
 - (b) Type of tank(s): (TK # 4, 5, 6) Tank - Fiberglass Double Wall XERXES*
 - (c) Type of piping: (TK # 4, 5, 6) Piping - Flexible Double Wall OPW Flexworks from tanks to dispensers as shown in site plan, (TK # 4, 5, 6) Piping - Other Steel Riser, (TK # 4, 5, 6) Piping - Other submersible pump, (TK # 4, 5, 6) Piping - Chase Secondary Containment OPW AXP - 4" secondary chase piping, (TK # 4, 5, 6) Piping - Ball Valves, (TK # 4, 5, 6) Piping - Shear Valves, (TK # 4, 5, 6) Piping - Flex Connector Steel, (TK # 4, 5, 6) Piping - Single Wall STP/Tanktop Sump XERXES Fiberglass*
 - (d) Product to be stored in each tank: (TK # 4) - Gasoline - Regular, (TK # 5) - Gasoline - Premium, (TK # 6) - Diesel Fuel*
 - (e) Type of leak detection being used:*
 - Tank: (TK # 4, 5, 6) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD, (TK # 4, 5, 6) Leak Detect - Tank - Interstitial Monitoring Veeder Root TLS 350*
 - Piping: (TK # 4, 5, 6) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 350 PLLD leak sensors, (TK # 4, 5, 6) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring Veeder Root in all submersible and dispenser sumps. NOTE: Sensors MUST shut down the submersible pump supplying that line upon detection of a leak per 175.640 a) 1)*
 - (f) Corrosion Protection being used:*
 - Tank: (TK # 4, 5, 6) Corrosion Prot - Tank - Fiberglass Non-Corrosive*
 - Piping: (TK # 4, 5, 6) Corrosion Prot - Piping - Flexible Non-Corrosive*
 - (g) Spill containment devices, piping and dispenser containment devices: (TK # 4, 5, 6) Spill Contain Device - Double Wall Spill Bucket OPW 1C-3132D Edge*
 - (h) Overfill prevention devices: (TK # 4, 5, 6) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-410C*
- (4)** The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov by calling (217)785-1020.
- (5) GENERAL REQUIREMENTS** : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All

steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

(6) SPECIAL CONTINGENCIES :

Install two (2) 15,000 gallon XERXES double wall USTs. One tank split 7,000/8,000 with concrete deadmen. Install OPW flexworks double wall flexible piping from new tanks to new dispenser sumps with secondary 4" chase piping. Install Veeder Root TLS-350 with CSLD and PLLD line leak detection, Veeder root intersitial sensors for two (2) tanks. Veeder root non-discriminating sump sensors for piping sumps (3) and dispenser sumps (2). Veeder root to have positive shut down per code. Upon completion, the site will be precision tested by third party testing company.


NOTE: Site plan shows the edge of the canopy to be 10'11" from property line, with the dispensers being further than that measurement, which meets the minimum distance for dispensers from property lines per section 175.450 f) 5)

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Superior Petroleum Marketers, Inc.
2336 Albright Lane P. O.Box 4648
Wheaton, IL 601894648

Contact Person: Steve Tuttle
Phone: (630) 588-1198
Contractor Registration # IL2087 Exp. 2/4/2020

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File