



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2000400
Permit # 00939-2019UPG
Request Rec'd 05/14/2019
Amended Date 08/12/2019 DS
Approval Date 5/14/2019 DS
Permit Expires 11/14/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Community Unit School District #200 2990 Raffel Road Woodstock, IL 60098 Contact: Gene Smith (815) 338-8204</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Woodstock School District #200 14126 W. South St Woodstock, IL 60098 Contact: Ken Roiland (815) 338-4777</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 4) - 10,500, (TK # 5) - 1,500

(b) Type of tanks:

(c) Type of piping:

(d) Product to be stored in each tank: (TK # 4) - Gasoline, (TK # 5) - Diesel Fuel

(e) Type of leak detection being used:

Tank: (TK # 4, 5) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS - 4c

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containment devices:

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

No overfill alarm was installed.

Only the Installation of Veeder Root TLS4c, and probes.

The existing overfill prevention OPW Drop tube valves to remain as overfill protection

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Stenstrom Petroleum Services Group

Contact Person: Robert Stenstrom

2422 Center Street
Rockford, IL 61108

Phone: (815) 398-6250
Contractor Registration # IL1890 Exp. 4/12/2020

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File