



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 4036468
Permit # 01543-2019REM
Request Rec'd 08/16/2019
Amended Date
Approval Date 8/16/2019 FS
Permit Expires 2/18/2020

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Prairie Holdings Newton, LLC 608 Bent Tree Drive Effingham, IL 62401 Contact: (217) 821-3236</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Circle K 103 West Jourdan Newton, IL 62448 Contact: Peggy Root (812) 379-9227</p>
--	---

(3) REMOVAL OF PIPING:

- (a) Description/location of piping being removed:*
- (b) Which tank(s) are associated with the piping being removed: (TK # 4) - 10,000*
- (c) Reason of piping being removed:*
- (d) If piping is leaking, indicate IEMA incident number:*

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES : REM permit issued after the fact. Removal of damaged piping and installation of new piping, both in a chase, reported to OSFM on an Emergency Repair Request. Request was denied due to scope of work exceeding an Emergency Repair and a removal being involved. REM and UPG permit applications submitted today. Inspector Weedman informed. Office staff putting the piping only removal on his schedule for today so a Log of Removal can be completed. Contractor informed that the procedure followed was not correct.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Neumayer Equipment Company, Inc. 5060 Arsenal Street St. Louis, MO 63139</p>	<p>Contact Person: Jimmy Spiros Phone: (314) 772-4501 Contractor Registration # IL1502 Exp. 3/26/2020</p>

Sincerely,

□
Fred Schneller

cc: Storage Tank Safety Specialist
Division File