



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4036468
Permit # 01544-2019UPG
Request Rec'd 08/16/2019
Amended Date
Approval Date 8/16/2019 FS
Permit Expires 2/18/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Prairie Holdings Newton, LLC 608 Bent Tree Drive Effingham, IL 62401 Contact: (217) 821-3236	(2) <u>FACILITY</u> - name and address where tanks are located: Circle K 103 West Jourdan Newton, IL 62448 Contact: Peggy Root (812) 379-9227
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 4) - 10,000

(b) Type of tanks:

(c) Type of piping: (TK # 4) Piping - Flexible Double Wall OPW Flexworks

(d) Product to be stored in each tank: (TK # 4) - Gasoline - Premium

(e) Type of leak detection being used:

Tank:

Piping: (TK # 4) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring Veeder Root

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containment devices:

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Repair already done under an Emergency Repair Request that was denied. Inspector will check on the removed piping and the new piping upgrade today, 8/16/2019.

Repair will help to comply pending NOV. Pending Emergency Repair Request was denied and is not a factor.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street

Contact Person: Jimmy Spiros

St. Louis, MO 63139

Phone: (314) 772-4501

Contractor Registration # IL1502 Exp. 3/26/2020

Sincerely,

□

Fred Schneller

cc: Storage Tank Safety Specialist
Division File