



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 1028432  
Permit # 01565-2019REM  
Request Rec'd 08/19/2019  
Amended Date  
Approval Date 8/20/2019 DS  
Permit Expires 2/20/2020

**Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Beck Oil Company of Illinois 850 E. Thompson St. Princeton, IL 61356  Contact: Gerri Frank (815) 315-0265</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Beck's #27 1302 Raymond Drive Mendota, IL 61342  Contact: Kevin Gerard (815) 539-3300</p>
--	--

(3) **REMOVAL OF PIPING:**

- (a) *Description/location of piping being removed:*
- (b) *Which tank(s) are associated with the piping being removed: (TK # 1, 2, 3) - 12,000, (TK # 4, 5) - 6,000*
- (c) *Reason of piping being removed:*
- (d) *If piping is leaking, indicate IEMA incident number:*

- (4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES :**

The diesel lines will be removed and run through a bioinjector pump. A total of 6 islands will be available for diesel. New electronic line leak detection, submersible pumps, tank sumps with sensors, and new pipe will be installed. A DEF tank will be installed also. The current EVO 550 will be upgraded. All of the gas islands will be removed and two additional islands will be added. New APT double wall pipe, electronic line leak detection, and sensors will be added to the sumps. The vents will be relocated from the building to the new canopy addition.

The existing spill containments will be removed and replaced with new.

**NOTE: An upgrade permit must be submitted for to replace the piping, sensors, sumps etc**

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Central Petroleum Equipment Company  
109 Terrace Dr.  
Blue Grass, IA 52726

Contact Person: Roger Clark  
Phone: (563) 381-5092  
Contractor Registration # IL345 Exp. 6/14/2020

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File