



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174 issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Mac's Convenience Stores, LLC 550 Warrenville Rd., Suite 400 Lisle, IL 60532 Contact: Charlene Troyer (630) 800-6065	(2) FACILITY - name and address where tanks are located: Circle K #1331 1619 E. Jackson Street Macomb, IL 61455 Contact: Nicole Anderson (812) 379-9227
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 6,000*

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 1) - Gasoline - Premium*

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices: (TK # 1) Spill Containment Device - Double Wall Spill Bucket OPW*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank For required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Replace existing spill container with new double wall spill container.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Neumayer Equipment Company, Inc.

Contact Person: Jimmy Spiros

5060 Arsenal Street
St. Louis, MO 63139

Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2020

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File