



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

FOR OFFICE USE ONLY
 Facility # 3017657
 Permit # 01576-2019UPG
 Request Rec'd 08/21/2019
 Amended Date
 Approval Date 8/21/2019 DS
 Permit Expires 9/4/2019

Permit for Emergency Repair Request on 8/20/2019

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Rajput, LLC 3401 4th Avenue Moline, IL 61265 Contact: Jangbir Thakur (563) 529-5007</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Rajput LLC 3401 4th Avenue Moline, IL 61265 Contact: Neeru Dadhwal (563) 529-5007</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:


- (a) *Number and size of tanks being upgraded or repaired: (TK # 8) - 4,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 8) Piping - Other Steel Riser*
- (d) *Product to be stored in each tank: (TK # 8) - Gasoline - Regular*
- (e) *Type of leak detection being used:*
 Tank:
 Piping:
- (f) *Corrosion Protection being used:*
 Tank:
 Piping:
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : We repaired two risers under dispenser #5 & #6 and did line test after repair was finished.

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	
<p>PIPECO, Inc. 610 29TH ST Bettendorf, IA 52722</p>	<p>Contact Person: Debbie Rindler Phone: (563) 344-0700 Contractor Registration # IL2034 Exp. 9/28/2020</p>

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File